



Summary of the 2009 CNGS TSG4 irradiation tests and perspectives for future tests and facilities

D.Kramer on behalf of the RADWG

Thanks to the users, CNGS experiment, J.Lendaro, D.McFarlane, M.Brugger, K.Roed, EN/MEF, DG/SCR, Fluka team and the RadMon team (T.Wijnands, A.Nyul, C.Pignard)



Outline

- ◆ CNGS test facility overview
- ◆ Calibration of test positions
- ◆ Results reported by users (tunnel / alcoves)

- ◆ CRYO
- ◆ BIC/PIC
- ◆ BLM
- ◆ BPM
- ◆ QPS
- ◆ CL heaters
- ◆ WorldFip
- ◆ Power Converters
- ◆ SURVEY

Fluka simulations for nominal beam assume

- 100fb^{-1}

ARC Fluka simulations use

- 10^7s $3.64 \times 10^{18}\text{p/s}$ 10^{15}mol/m^3

2010 luminosity assumed as

- 0.5fb^{-1}

2010 ARC losses assumed as

- 1/40 of nominal

- ◆ Foreseen test activities in 2010
- ◆ Conclusions

Nominal year
assumed as 200 days





Testing area in the TSG4 side gallery of CNGS

Temporary procedure for handling irradiated electronics was put in place for CNGS. Valid until 30/11/09 and extended from 19 Jan 2010. RADIOACTIVE electronics WORKSHOP has to be used afterwards.

Mixed radiation fields similar to the ones expected in LHC

Measured quantities:

- Dose (SiO_2)
- Hadron $>20\text{MeV}$ fluence
- $1\text{MeV } n^0$ eq. fluence







Testing area in the TSG4 side gallery of CNGS

Temporary procedure for handling irradiated electronics was put in place for CNGS. Valid until 30/11/09 and extended from 19 Jan 2010. RADIOACTIVE electronics WORKSHOP has to be used afterwards.

Mixed radiation fields similar to the ones expected in LHC

> 20 MeV Hadron fluence per primary at station level ($-150 \text{ cm} < y < -90 \text{ cm}$)




Courtesy of K.Roed

27 Jan 2010

RADWG for Chamonix




2 Test areas – High & Low flux with multiple calibrated locations



Hottest test area in TSG46:
~ 3.3 Gy(SiO₂)/week
~ 1.8 10¹⁰(>20MeV)cm⁻²/week


1 Week ~ 1e18pot

Hottest test area in TSG45 :
~ 28 Gy(SiO₂)/week
~ 1.9 10¹¹(>20MeV)cm⁻²/week
This is expected in the LHC arcs* in
3 nominal years (10Gy/y)





Calibrated radiation field data for all test locations accessible via dedicated Java GUI



Like it is the case for FLUKA, Safety Factor of 2 has to be used for all the CNGS measurements (high gradients, small detector size) for **CUMULATIVE** effects

By assuming all the devices to be installed in the worst locations, the estimations are **more conservative than 2 times!** (for SEE related failures)

All the user requests could be fulfilled in 2009 in CNGS at the expense of very crowded periods in the High Dose area (tunnel equip.)



User test results

- ◆ **CRYO**
- ◆ **BIC/PIC**
- ◆ **BLM**
- ◆ **BPM**
- ◆ **QPS**
- ◆ **CL heaters**
- ◆ **WorldFip**
- ◆ **Power Converters**
- ◆ **SURVEY**



Data provided by E.Gousiou



CRYO Tunnel Electronics

9500** channels in LHC

OK

Equip. tested in CNGS:

- Temperature reading (18 Channels)
- Helium level reading (12 Channels)
- Digital inputs (24 Channels)
- Cold mass electrical heater DC supply (4 Channels)
- FIP communication (8 agents)
- Power supply (2 cards)

ARC annual levels below MBB

- ◆ $4e9cm^{-2}$ $E>20MeV$
- ◆ 1Gy

2009/10

- ◆ $1e8cm^{-2}$ $E>20MeV$
- ◆ 25mGy

Observed Errors in CNGS

None**, accuracy within specs

| Safety factor 2x to be applied for all cumulative effects in this talk | | Lifetime in LHC years / MTBF (channel) | Mitigation |
|--|-------------|--|---|
| TID | >500 Gy | 500 (12 in DS*) | Not needed. Upper limit on channel failure rate Largely overestimated |
| Channel failure cross section upper limit | $3e-13cm^2$ | >18 days** | |
| MTBF in 2010 lower limit | | >3.6y** | |

*Some cards up to MBB8 – monitoring required



CRYO - Protected Areas

Cumulative effects

Equip. tested in CNGS:

- A. 6 QRL electrical heater AC supplies (45 in LHC)
- B. 12 Insulated temperature conditioners (2400 in LHC)

Observed Errors in CNGS

- A. Solid State Relay damaged
- B. DC-DC converter fails

Annual fields in worst location UJ56,14,16

- ◆ $5e9\text{cm}^{-2} E>20\text{MeV}$
- ◆ 5Gy

2010

- ◆ $2.5e7\text{cm}^{-2} E>20\text{MeV}$
- ◆ 25mGy

| A – QRL heater | OK if | Mitigation |
|------------------|-------|---|
| TID | 10Gy | Will be cured by shielding (& relocation in case of UJ56 to bottom floor) |
| Nominal lifetime | 2y | |
| Lifetime in 2010 | 400y | |

| B – Insul. temp. | OK | Mitigation |
|------------------|-------|------------|
| TID | 140Gy | Not needed |
| Nominal lifetime | 28y | |
| Lifetime in 2010 | OK | |

Only used during machine cool down – with no beam



CRYO - Protected Areas

Single Event Errors

Equip. tested in CNGS:

Insulated Temperature Conditioners

Number in alcoves:

2400 channels

Observed Errors in CNGS

SEU on digital isolator

Annual fields in worst location UJ56,14,16

- ◆ $5e9cm^{-2}$ $E>20MeV$
- ◆ 5Gy

2010

- ◆ $2.5e7cm^{-2}$ $E>20MeV$
- ◆ 25mGy


| | | Mitigation |
|--------------------------------------|------------|--|
| Failure cross section (per channel) | $2e-9cm^2$ | soft reset |
| MTBF if all in UJ56 for nominal beam | 0.2h | automatically forced by the control system (WFip) <u>in progress</u> |
| MTBF in 2010 | 1.7days | |

OK if



User test results

- ◆ CRYO
- ◆ **BIC/PIC**
- ◆ BLM
- ◆ BPM
- ◆ QPS
- ◆ CL heaters
- ◆ WorldFip
- ◆ Power Converters
- ◆ SURVEY



XC95144 x 32
XC95288**XL** x 32

Data provided by M.Zerlauth & B.Todd



BIC - Protected Areas

SEEs of CPLD 3.3V [component test]

Equip. tested in CNGS:

XILINX CPLD XC9500XL 3.3V
part of BIS signal path (critical)

Number in alcoves:

36

Observed Errors in CNGS

- A. 20% of SEUs cause loss of redundancy
- B. 80% of SEUs cause false dump

Annual fields in worst location UA87,23

- ◆ $5e7\text{cm}^{-2}$ $E>20\text{MeV}$
- ◆ 0.05Gy

2010

- ◆ $1e7\text{cm}^{-2}$ $E>20\text{MeV}$
- ◆ 10mGy

| A / B | | Mitigation |
|---------------------------------------|----------------------|--|
| SEU cross section (per device) | $2.8e-10\text{cm}^2$ | New quick shielding effective by factor ~10 for TED, maze near TCDI,TDI to be reinforced. Simulations to be performed. |
| MTBF* loss of redundancy / false dump | 10y / 2.5y | |
| Fault probability in 2010 | $2e-2$ / $8e-2$ | |

*if all in UA87 for nominal beam no shielding

Thermal neutron sensitivity could be an issue with 3.3V



BIS/PIC - Protected Areas

SEEs of CPLD 5V [component test]

Equip. tested in CNGS:

XILINX CPLD XC9500 5V part of BIS/PIC monitoring paths

Number in alcoves:

336 (CIBUs – 300, PIC - 36)

Observed Errors in CNGS

- A. 90% of SEUs cause monitoring problem
- B. 10% of SEUs cause false dump

Annual fields in worst location RRs

- ◆ $1e9cm^{-2}$ $E>20MeV$
- ◆ 1Gy

2010

- ◆ $5e6cm^{-2}$ $E>20MeV$
- ◆ 5mGy

OK

| A / B | | Mitigation |
|---------------------------------------|-----------------|--|
| SEU cross section (per device) | $3.8e-13cm^2$ | MTBF ~same as electrical reliability of the CPLD! Relocations from UJ56,14,16 fully prepared so not considered here (contain PLCs). |
| MTBF* monitoring problem / false dump | 8y / 72y | |
| Fault probability in 2010 | $6e-4$ / $7e-5$ | |


*if all in RR13 for nominal beam

Destructive Latchups of CPLDs should have very low probability in shielded areas due to lower peak energy



User test results

- ◆ CRYO
- ◆ BIC/PIC
- ◆ **BLM**
- ◆ BPM
- ◆ QPS
- ◆ CL heaters
- ◆ WorldFip
- ◆ Power Converters
- ◆ SURVEY



Data provided by E.Effinger



BLM - Protected Areas and ARCs

Cumulative and SEE effects

OK

Equip. tested in CNGS:

- A. Power Supply Haltec 2.5V (37x)
- B. Power Supply Haltec 5V (74x)
- C. BLECF tunnel card, PS (600x)

Observed Errors in CNGS

- A. Total dose effects, voltage drop
- B. Total dose effects, voltage drop
- C. 1 SEE leading to false dump

Annual fields in worst location RR13 / ARC (MQ)

- ◆ $1e9 / 4e10 \text{ cm}^{-2} E>20\text{MeV}$
- ◆ $1 / 10 \text{ Gy}$

2010

- ◆ $5e6 / 1e9 \text{ cm}^{-2} E>20\text{MeV}$
- ◆ $5 / 250 \text{ mGy}$

| A,B Power Supplies | | Mitigation |
|--------------------|---------|------------|
| TID | 85/33Gy | Not needed |
| Nominal lifetime | 85/33y | |
| Lifetime in 2010 | OK | |

| B – BLECF | | Mitigation |
|-------------------|----------------------|--|
| TID | 750Gy | Not needed, handled by remote reset via HV |
| Nominal lifetime | 75y | |
| SEE cross section | $1.9e-13\text{cm}^2$ | |
| MTBF | 44days | |
| MTBF in 2010 | 8.8y | |



User test results

- ◆ CRYO
- ◆ BIC/PIC
- ◆ BLM
- ◆ **BPM**
- ◆ QPS
- ◆ CL heaters
- ◆ WorldFip
- ◆ Power Converters
- ◆ SURVEY



Data provided by E.Calvo



BPM – tunnel electronics

Equip. tested in CNGS:

- A. Intensity card (330x) Not OK but
- B. Power Supply (330x) OK
- C. WorldFIP card (330x)
- D. 2 WBTN cards (2160x) OK

Observed Errors in CNGS

- A. After SEE out of range readings
- C. After SEE, WBTN calibration off and High sens. mode, max 250um offset for 1min

Annual fields in worst location - ARC (MQ)

- ◆ $4e10 \text{ cm}^{-2} E>20\text{MeV}$
- ◆ 10 Gy

2010

- ◆ $1e9 \text{ cm}^{-2} E>20\text{MeV}$
- ◆ 0.25 Gy

Not OK but


| A Int. card / B,C,D WBTN | | Mitigation |
|--------------------------|-----------|---|
| TID | 4/>230Gy | Card needed only for initial operation at low intensity |
| Nominal lifetime | 0.4y/>23y | |
| Lifetime in 2010 | 16y/920y | |

| C – WorldFIP card | | Mitigation |
|-------------------|--------------------|--|
| SEE cross section | $4e-12\text{cm}^2$ | Channel can be masked by the orbit feedback system |
| MTBF | 3.8days | |
| MTBF in 2010 | 152days | |



User test results

- ◆ CRYO
- ◆ BIC/PIC
- ◆ BLM
- ◆ BPM
- ◆ **QPS**
- ◆ CL heaters
- ◆ WorldFip
- ◆ Power Converters
- ◆ SURVEY



Data provided by R.Denz



nQPS – LHC ARCs [new QPS layer]

Equip. tested in CNGS:

Field-bus coupler type DQAMGS

Number in tunnel: 450

Observed Errors in CNGS

SEE in uFip or FieldDrive freezes the supervision path – access needed prior to

next fill to restart the card. Observed analog drifts do not pose problems

Annual fields in ARCs
under dipoles

- ◆ $4e9\text{cm}^{-2}$ $E>20\text{MeV}$
- ◆ 1Gy

2010

- ◆ $1e8\text{cm}^{-2}$ $E>20\text{MeV}$
- ◆ 25mGy

| | | Mitigation |
|--------------------------------|----------------------|---|
| SEU cross section (per device) | $2.8e-10\text{cm}^2$ | Automatic reset of the WorldFIP. Solution tested successfully in CNGS . To be implemented when the errors start to appear. |
| MTBF nominal beam | 10h | |
| MTBF in 2010 | 16d | |


Not OK but

“2009 tests in CNGS confirmed the radiation tolerance of the detection systems of the new QPS layer including the power supplies. Detailed evaluation still to be done”



User test results

- ◆ CRYO
- ◆ BIC/PIC
- ◆ BLM
- ◆ BPM
- ◆ QPS
- ◆ **CL heaters**
- ◆ WorldFip
- ◆ Power Converters
- ◆ SURVEY



Data provided by S.Le Naour



Current Lead heaters – protected areas

Equip. tested in CNGS:

7 Regulators and Solid State Relays
(UJ&RRs 408x, others not counted: 904x)

Observed Errors in CNGS

Destructive SEE in the regulator –
ice formation on DFB after dump =>
Cryo Start removed

Annual fields in the worst location i.e. UJ56

- ◆ $5e9 \text{ cm}^{-2} E>20\text{MeV}$
- ◆ 5 Gy

2010

- ◆ $2.5e7 \text{ cm}^{-2} E>20\text{MeV}$
- ◆ 25 mGy


| Temperature regulator | | Mitigation |
|-----------------------|----------------------|---|
| SEE cross section | $2e-11 \text{ cm}^2$ | Not critical for the operation. Only 84 devices in UJs. <u>Shielding will help</u> |
| MTBF | 5days | |
| MTBF in 2010 | 5y | |

Not OK but



User test results

- ◆ CRYO
- ◆ BIC/PIC
- ◆ BLM
- ◆ BPM
- ◆ QPS
- ◆ CL heaters
- ◆ **WorldFip**
- ◆ Power Converters
- ◆ SURVEY



Planned development of the new nanoFIP is covered in the talk of J.Serrano

Data provided by J.Palluel



WorldFIP – signal repeaters in the tunnel

OK

Equip. tested in CNGS:

2 Repeaters Cu-Cu (320x in ARC)

Observed Errors in CNGS

Total dose effect – replacement required before beam on

Annual fields in worst location - ARC along MB

- ◆ $4e10 \text{ cm}^{-2} E>20\text{MeV}$
- ◆ 10 Gy

2010

- ◆ $1e9 \text{ cm}^{-2} E>20\text{MeV}$
- ◆ 0.25 Gy

| Repeater | | Mitigation |
|--------------------------|------------------------|--|
| TID | 165/>250Gy | Device inspected yesterday – drift in an auxiliary part. Annual dose overestimated (cable tray). |
| Fluence $h>20\text{MeV}$ | $1.1e12\text{cm}^{-2}$ | |
| ARC lifetime | 16y | |



User test results

- ◆ CRYO
- ◆ BIC/PIC
- ◆ BLM
- ◆ BPM
- ◆ QPS
- ◆ CL heaters
- ◆ WorldFip
- ◆ **Power Converters**
- ◆ SURVEY



For detailed results please look in the talk of Y.Thurel

Data provided by Y.Thurel, S.Dubettier



Power Converters – tunnel and part of alcoves electronics

Equip. tested in CNGS:

- A. FGC COD (752xARCs)
- B. FGC Generic (189+256xUJs,RRs)
- C. High precision part SD360 (as B.)
- D. Component tests

Annual fields in worst location – UJ56 / ARC

- ◆ $5e9 / 4e9 \text{ cm}^{-2} E>20\text{MeV}$
- ◆ 5 / 1 Gy

Observed Errors in CNGS

- A. B. Crashes of FGC requiring power cycle and therefore dump (so far unexplained - half SEL of CPLD?)
- C. Very frequent corruptions only in 350**, 360 OK (more tests needed)

2010

- ◆ $2.5e7 / 1e8 \text{ cm}^{-2} E>20\text{MeV}$
- ◆ 25 / 25 mGy

**Corruptions of SD350 (Generic FGC) are rather critical due to large cross section

| A (ARC) / B (UJs) FGCs | | Mitigation |
|------------------------|----------|--|
| TID | OK | No problems expected from cumulative effects |
| Nominal lifetime | 100y/20y | |
| Lifetime in 2010 | OK | |


| A+B – FGC | Not OK? | Mitigation |
|---------------------|------------------------|--|
| SEE cross section * | $2.3e-11 \text{ cm}^2$ | Shielding will help in UJs,RRs not in ARCs. <u>REDUNDANT!</u> |
| MTBF * | 1.8days | |
| MTBF in 2010 | 72days | |

All crashes occurred only at low fluence -> uncertainty in cross section.
If total fluence considered, MTBF = 7days



User test results

- ◆ CRYO
- ◆ BIC/PIC
- ◆ BLM
- ◆ BPM
- ◆ QPS
- ◆ CL heaters
- ◆ WorldFip
- ◆ Power Converters
- ◆ **SURVEY**



Data provided by A.Marin



SURVEY– controller electronics from protected areas

Equip. tested in CNGS:

1 Controller crate (6x,UJ56)

Annual fields in worst location – UJ56

- ◆ $5e9 \text{ cm}^{-2} E>20\text{MeV}$
- ◆ 5 Gy

Observed Errors in CNGS

- Cumulative effect failure, drifts very small
- System crashes (likely SEE in the uFip) requiring remote reset via WorldFip, no beam dump

2010

- ◆ $2.5e7 \text{ cm}^{-2} E>20\text{MeV}$
- ◆ 25 mGy

Triplet motor drivers should remain OFF during beam operation (in the same rack)

| a) | OK | Mitigation |
|------------------|-------|--|
| TID | 100Gy | No problems expected from cumulative effects |
| Nominal lifetime | 20y | |
| Lifetime in 2010 | OK | |

| b) | OK | Mitigation |
|-------------------|--------------------|--|
| SEE cross section | $8e-12\text{cm}^2$ | System can remain in 1 st floor of UJ56 w/o shielding |
| MTBF | 4y | |
| MTBF in 2010 | 800y | |



List of tests for LHC electronics in external facilities in 2009

- ◆ **PSI proton beams 60/250MeV used by**
 - ◆ **QPS for component tests**
 - ◆ **WIC for Siemens remote I/Os**
 - ◆ **RadMon for calibrations**
- ◆ **CEA Valduc 1MeV n, 14/5MeV n**
 - ◆ **BLM, CRYO for NIEL**
 - ◆ **RadMon calibrations**
- ◆ **UCL Louvain la Neuve Heavy ions**
 - ◆ **CPLD tests**
- ◆ **NRI Prague (epi)thermal n**
 - ◆ **RadMon calibration**
 - ◆ **Repeater test**
- ◆ **IRA Lausanne Co60**
 - ◆ **RadMon calibrations**



Conclusions – no bad surprises

- ◆ Very **large effort** has been dedicated by the **equipment groups** to the radiation tolerance **tests** in CNGS!
- ◆ **Most** of the electronics systems from the LHC **tunnel** were **tested** in CNGS TSG4 in similar spectra as expected in the LHC
- ◆ Small **part** of the systems from the **alcoves** (RRs, UJs, ..) **tested** as well
- ◆ Resulting lifetimes from cumulative effects and failure rates from single events were estimated for nominal beam conditions and for 2010 (0.5fb^{-1}) – see the following **Summary Table**
- ◆ Many systems suffer from errors in the WorldFip modules (BPM, nQPS, CRYO, SURVEY) - the **nanoFIP** is expected to **help** in some cases
- ◆ Most issues solved by **HW/FW modifications**
- ◆ Several systems rely on the **shielding** improvements
- ◆ The BPM intensity card fails at low dose but is required just for commissioning
- ◆ The very complex issue of power converters is better covered in the separate talk of Yves



Outlook

- ◆ Several users want to do more tests in 2010 at CNGS
 - ◆ **CRYO, QPS, TE/EPC**
- ◆ n_TOF could be eventually used as similar facility (2 options) if too many requests for CNGS (unlikely in 2010/11)
 - ◆ **Modifications would have to be started very soon**
 - ◆ **Mixed field close to target**
 - ◆ **Broad n^0 spectrum with rather low flux**
- ◆ HiRadMat can also be accommodated to host the mixed field electronics tests
 - ◆ **Requests from users would be required to support the decision**
- ◆ Sharing of test experiences, beam times (=expenses) and results through RADWG can be very helpful

Failure rate and lifetime estimations for 2010 and nominal LHC

| SYSTEM | subsystem | MTBF | Lifetime with nominal beam | MTBF 2010 | Lifetime 2010 |
|------------|-------------------|---------|----------------------------|-----------|---------------|
| CRYO | Tunnel channels | >18d | 500 (12y DS) | >3.6y | ∞ |
| | Ins. Temp reading | 0.2h | 28y | 12d | ∞ |
| | QRL heater PS | | 2y | | ∞ |
| BIC/PIC | BIS I.o.r./dump | 10/2.5y | | 50/12.5y | ∞ |
| | Monitoring/dump | 8/72y | | ∞ | ∞ |
| BLM | PS 2.5/5V | | 33/85y | | ∞ |
| | BLECF | 44d | 75y | 8.8y | ∞ |
| BPM | WBTN | 3.8d | 23y | 0.75y | ∞ |
| | Intensity card | | 0.4y | | 16y |
| QPS | nQPS | 10h | | 16d | |
| CL heaters | Temp. controller | 5d | | 5y | |
| WFip rep. | ARC | | 16y | | ∞ |
| Power Co. | FGC ARC/UJs | 1.8d | 100/20y | 72d | ∞ |
| Survey | Control crate | 4y | 20y | ∞ | ∞ |

Lifetime estimations should be divided by safety factor 2



Backup slides - Radmon Calibrations

- ◆ The Hadron $>20\text{MeV}$ sensitivity is quite well understood in forward shower regions – very good match with Fluka
 - ◆ Excellent result behind the TED
 - ◆ Most of the CNGS positions (match in line of sight to target chamber)
 - ◆ CERF calibration campaign explored combinations of various settings and fields
- ◆ Several measurements done in different neutron fields to determine the sensitivity below 20MeV
 - ◆ Analysis to be finalized
 - ◆ Measurements at PTB mono-energetic neutron beams are scheduled for 2010
- ◆ Dose sensitivity calibration measurements yet to be extended to higher doses
 - ◆ Calibration in Co60 gamma field
- ◆ 1MeV n equivalent fluence calibration to be reviewed for higher fluences
 - ◆ Calibration in neutron field of air cooled U235 reactor – data available