




Safety Commission

European Organization for Nuclear Research - Organisation européenne pour la recherche nucléaire

# Safety Task force follow-up in perspective to the 2<sup>nd</sup> LHC physics run in 2011

R. Trant

# Safety follow-up of 19<sup>th</sup> Sept. 2008 incident




- “Safety Task Force”  
*SC, BE, EN, PH, TE, Staff Ass.*  
[\[CERN-ATS-2009-002\]](#)
- *External Advisory Committee*  
[\[CERN-ATS-2009-003\]](#)
- All recommendations endorsed by directorate
- All safety measures required for 2009/10 run implemented

# Task force conclusions

- All efforts have to be made to **limit** an incidental helium release and the resulting overpressure.
- Any incidental helium release shall be **confined** to the ventilation sector where it occurs.
- This confinement must be carried out in combination with a **controlled release** of overpressure to the surface.
- **No access** shall be allowed to any ventilation sector of the LHC in which a large helium release has a non-negligible probability to occur. ...

# Recall of MCI scenario

Worst case scenario	Maximum flow [kg/s]	Helium inventory loss [t]	
		Fast release (During the first minutes) [t]	Total [t]
1999 analysis (Break of jumper connection)*	20	0.6	4.3
19 <sup>th</sup> Sept. 2008 incident	~ 26	~ 2	~ 6
2009 analysis (Electrical arc in mid-arc sub-sector)	40**	1.5	5



# Implementation status of TF recommendations

Recommendation Number	Closed issues	Open issues being implemented	Open issues
# 1			
# 2			
# 3			
# 4			
# 5		✓	
# 6			✓
# 7	✓		
# 8	✓		
# 9	✓		
# 10	✓		
# 11	✓		
# 12		✓	
# 13		✓	
# 14		✓	

The sealing of the LHC tunnel towards other underground areas to protect them from Oxygen Deficiency Hazard (ODH) and from possible overpressure.

The surface task force recommends the implementation of a study group to propose possible options. One such option is to use the existing ventilation ducts equipped with overpressure relief devices and reinforced to withstand the high mass-flow rates.



# Additional recommendations by EAC – status

*[only the open issues]*

- “... The existing **risk matrices** from 1999 should be **systematically reviewed** again with regard to the latest experiences. ...”  
[Preliminary risk analysis of the LHC cryogenic system, M. Chorowski, *et al.*, *LHC-Project-Note-177*, (1998)]  
→ **open issue being addressed**
- ... a strong consideration to **formally track the progress** of each recommendation, ...  
→ **open issue being addressed**
- The **2-Phase approach** ... technical implementation of the ... control for tunnel access ... not clear whether the control will be connected to the **access interlock**.  
→ **open issue being addressed**

# Open issues: being addressed or scheduled for next shut down

1. The **consolidation/repair** of potentially faulty bus-bar interconnects in the LHC machine together with the implementation of the **improved machine protection systems** (e.g. quench protection system, overpressure relief valves, etc.) shall be completed before repowering the magnets.
2. In addition, to limit incidental release at lower flow-rates the **liquid helium shall be removed** from the LHC machine before going into machine **shutdown** mode.
5. A **detailed calculation of the overpressure values** is recommended. This calculation should be done by means of Computational Fluid Dynamics software tool offering the possibility to take into account time dependant flow rates, helium gas expansion, thermal exchange with tunnel components, He/O<sub>2</sub> concentrations etc..



# Open issues: being addressed or scheduled for next shut down

12. Equip machine tunnel sectors with **sensors to monitor** air temperature and pressure, as well as air speed in the tunnel.
13. Carry out a **risk assessment of particularities** such as the He-Ring line and the cryogenic installations in the UX45, UX65, and UX85 caverns.
14. The Safety Task Force considers that the **ventilation system** is relevant for the safety of personnel and thus recommends to set-up a study of the LHC ventilation system with respect to **monitoring and reliability** of the system.



# Open issues

## Recommendation # 6

- For the **guided release of static overpressure from the LHC tunnel to the surface**, the Safety Task Force recommends the implementation of a study group to propose possible options. ...
  - **WG\* “Safety Task Force follow-up: 2nd phase” started in Dec. 2009 – chaired by Sylvain Weisz**

## Recommendation # 3

- The **sealing of the LHC tunnel towards other underground areas** to protect them from Oxygen Deficiency Hazard (ODH) and from possible overpressure.
  - **WG\* “Safety Task Force follow-up: 2nd phase” started in Dec. 2009 – chaired by Sylvain Weisz**

\* This WG follows up all the recommendations made by the TF & EAC



European Organization for Nuclear Research - Organisation européenne pour la recherche nucléaire

# Thank you